




Certificate N° 211969

**TESTS OF AIR PERMEABILITY, WATER TIGHTNESS AND WIND RESISTANCE**

Company	<b>Anicolor Aluminios LDA Oliveira do Bairro. Portugal</b>
Product	<b>Two-paned hinged window with rotation about vertical axis, opening towards the interior.</b>
Model	<b>Serie: A1-A6</b>
Dimensions (AnxAI)	<b>1230 mm x 1480 mm</b>
Material	<b>Aluminio</b>
Glass	<b>4/10/4</b>
Date of test	<b>19.05.09</b>

Procedure of test:  
 DIN EN 1026:2000. Windows and doors - Air permeability - Test method  
 DIN EN 1027:2000. Windows and doors - Watertightness - Test method.  
 DIN EN 12211:2000. Windows and doors - Resistance to wind load. Test method

Section



**Air Permeability CLASS 2**  
**Water Tightness CLASS 7A**  
**Wind resistance CLASS C3**



Procedure of classification  
 DIN EN 12207:2000. Windows and doors - Air permeability. Classification  
 DIN EN 12208:2000. Windows and doors - Watertightness. Classification  
 DIN EN 12210:2000. Windows and doors - Resistance to wind load. Classification  
 DIN EN 12210-AC:2002. Windows and doors - Resistance to wind load. Classification

Oscar Ruiz Chicote  
Person in charge of the area

Luis García Viguera  
The director department construction

José Morales Henares  
General Manager

The present certification is coincidental with the report of test N° 211969