

RESULTS SUMMARY REPORT

– UME045/16 –

Based in the test report ACL112/16 of 24/06/2016

Date: 24/06/2016

Test Owner: Anicolor – Alumínios, Lda.

Address: Zona Industrial de Oiã, Apartado 6 | 3770-059 Oiã

Contact name: Sr. José António Pinto


Tel.: +351 234 729 420

e-mail: tecnico@anicolor.pt

Tested specimen:

It was submitted for testing one specimen with the internal reference ACL115A/16, which had the following customer reference:

System AJi Hidden Leaf Channel 16



Test specimen (ACL115A/16)

This specimen consisted in a window in aluminum with thermal break, composed by one tilt-and-turn casement, with the following dimensions (W×H): 1230 mm × 1480 mm.


Performed test and results:

The test performed to the ACL115A/16 specimen and its results were the following:

Test:	Results: R_w (C; C_{tr} ; $C_{100-5000}$; $C_{tr 100-5000}$)
Laboratory test: Measurement of airborne sound reduction index (ISO 10140-1:2010, ISO 10140-2:2010, ISO 10140-4:2010 e ISO 717-1:2013)	38 (-2; -5; -1; -5) dB

Note: This report is not a replacement for the individual test report which served as its basis. For a complete analysis and interpretation of the results see individual test report.

Report author: 

Technical supervisor: 
(Technical and Scientific Supervisor)

Administration: 