



Document N° 218463


**DETERMINATION OF THE RESISTANCE
TO THE STATIC TWIST.**

Empresa **Anicolor, Aluminios LDA.
Oliveira do Bairro. Portugal.**

Normas de Ensaio:
UNE-EN 14609:2004. Une résistance à la
torsion statique

Produto	Flip-top window of vertical and horizontal low practicable draft to the interior of two leaves right.
Modelo	Series: AKI
Dimensões (LxH)	1800 mm x 2200 mm
Material	Alumínio
Tipologia do vidro	5/16/5
Data do Ensaio	13.05.10

Section



CLASSIFICATION **SUITABLE**
RESISTANCE TO THE STATIC TWIST. **350 N**



Oscar Ruiz Chicote
Responsable de Area

Luis García Viguera
Responsable Departamento

José Alvarez Burgué
Director Técnico

The present certification is coincidental with the report of test N° 218463