




Certificate N° 212086

TESTS OF AIR PERMEABILITY, WATER TIGHTNESS AND WIND RESISTANCE

Company	Anicolor Aluminios LDA Oliveira do Bairro. Portugal
Product	Flip-top window of vertical and horizontal low practicable draft to the interior of two leaves right.
Model	Serie: Sistema ARI
Dimensions (AnxAI)	1230 mm x 1480 mm
Material	Aluminio
Glass	5/14/5
Date of test	19.05.09

Procedure of test.
 DIN EN 1026:2000 Windows and doors - Air permeability - Test method
 DIN EN 1027:2000 Windows and doors - Watertightness. Test method
 DIN EN 12211:2000. Windows and doors - Resistance to wind load - Test method

Section



Air Permeability CLASS 4

Water Tightness CLASS E₇₅₀

Wind resistance CLASS C5



Procedure of classification
 DIN EN 12207:2000. Windows and doors - Air permeability. Classification
 DIN EN 12208:2000. Windows and doors - Watertightness. Classification
 DIN EN 12210:2000. Windows and doors - Resistance to wind load. Classification
 DIN EN 12210 AC:2002. Windows and doors - Resistance to wind load Classification

Oscar Ruiz Chicote
Person in charge of the area

Luis García Viguera
The director department construction

José Morales Henares
General Manager

The present certification is coincidental with the report of test N° 212086