



Certificate N° 213211


**TESTS OF AIR PERMEABILITY, WATER TIGHTNESS
AND WIND RESISTANCE**

Company **Anicolor Aluminios LDA**
Zona Industrial Oiã, Apartado 6. Oiã.
Oliveira Do Bairro. Portugal.

Product	Flip-top window of vertical and horizontal low practicable draft to the interior of two leaves right.
Model	Serie: Sistema ATi
Dimensions (AnxAI)	1230 mm x 1480 mm
Material	Aluminio
Glass	4/12/4
Date of test	30.07.09

Procedure of test
DIN EN 1026:2000. Windows and doors.
- Air permeability - Test method
DIN EN 1027:2000. Windows and doors. Watertightness. Test method
DIN EN 12211:2000. Windows and doors. Resistance to wind load. Test method

Section



Air Permeability **CLASSE 4**
Water Tightness **CLASSE 9A**
Wind resistance **CLASSE C5**



Procedure of classification
DIN EN 12207:2000. Windows and doors. Air permeability. Classification
DIN EN 12208:2000. Windows and doors. Watertightness. Classification
DIN EN 12210:2000. Windows and doors. Resistance to wind load
Classification
DIN EN 12210 AC:2002. Windows and doors. Resistance to wind load
Classification

Oscar Ruiz Chicote
Person in charge of the area

Luis García Viguera
The director department construction

José Morales Henares
General Manager

The present certification is coincidental with the report of test N° 213211