



Document N° 218468


**DETERMINATION OF THE RESISTANCE  
TO THE STATIC TWIST.**

Empresa **Anicolor, Aluminios LDA.  
Oliveira do Bairro. Portugal.**

Normas de Ensaio:  
UNE-EN 14609:2004. Une résistance à la  
torsion statique

Produto	<b>Flip-top window of vertical and horizontal low practicable draft to the interior of two leaves right.</b>
Modelo	<b>Series: ATI</b>
Dimensões (LxH)	<b>1800 mm x 2200 mm</b>
Material	<b>Alumínio</b>
Tipologia do vidro	<b>4/12/4</b>
Data do Ensaio	<b>13.05.10</b>

Section



**CLASSIFICATION** **SUITABLE**  
**RESISTANCE TO THE STATIC TWIST.** **350 N**



Oscar Ruiz Chicote  
Responsable de Area

Luis García Viguera  
Responsable Departamento

José Alvarez Burgué  
Director Técnico

The present certification is coincidental with the report of test N° 218468