



Document N° 218469

TESTS OF AIR PERMEABILITY, WATER TIGHTNESS AND WIND RESISTANCE


Company **Anicolor, Aluminios LDA.**
Oliveira do Bairro. Portugal

Procedure of test:
DIN EN 1026:2000. Windows and doors - Air permeability - Test method
DIN EN 1027:2000. Windows and doors. Watertightness. Test method.
DIN EN 12211:2000. Windows and doors. Resistance to wind load. Test method.

Product **Exterior pedestrian flip-top door of vertical, practicable draft on the outside of two leaves right.**

Section

Model	Series: AX- Milenio
Dimensions (AnxAI)	1700 mm x 2000 mm
Material	Aluminiio
Glass	3+3
Date of test	14.04.10




Air Permeability **CLASS 2**

Water Tightness **CLASS 0**

Wind resistance **CLASS C3**

Procedure of classification:
DIN EN 12207:2000. Windows and doors. Air permeability. Classification.
DIN EN 12208:2000. Windows and doors. Watertightness. Classification.
DIN EN 12210:2000. Windows and doors. Resistance to wind load. Classification.
DIN EN 12210/AC:2002. Windows and doors. Resistance to wind load. Classification.



Oscar Ruiz Chicote
Person in charge of the area

Luis García Viguera
The director department construction

José Alvarez Burgué
The Technical director

The present certification is coincidental with the report of test N° 218469