




Certificate N° 215108

**TESTS OF AIR PERMEABILITY, WATER TIGHTNESS  
AND WIND RESISTANCE**


Company	<b>Anicolor, Aluminios LDA. Oliveira do Bairro. Portugal</b>
Product	<b>Flip-top window of vertical and horizontal low practicable draft to the interior of two leaves right.</b>
Model	<b>Series: Sistema AX</b>
Dimensions (AnxAI)	<b>1230 mm x 1480 mm</b>
Material	<b>Aluminio</b>
Glass	<b>5/14/5</b>
Date of test	<b>12.11.09</b>

Procedure of test:  
DIN EN 1026:2000. Windows and doors -  
Air permeability - Test method  
DIN EN 1027:2000. Windows and doors.  
Watertightness. Test method.  
DIN EN 12211:2000. Windows and  
doors. Resistance to wind load. Test  
method.

Section



<b>Air Permeability</b>	<b>CLASS 4</b>
<b>Water Tightness</b>	<b>CLASS E<sub>900</sub></b>
<b>Wind resistance</b>	<b>CLASS C5</b>



Procedure of classification:  
DIN EN 12207:2000. Windows and  
doors. Air permeability. Classification.  
DIN EN 12208:2000. Windows and  
doors. Watertightness. Classification.  
DIN EN 12210:2000. Windows and  
doors. Resistance to wind load.  
Classification.  
DIN EN 12210/AC:2002. Windows and  
doors. Resistance to wind load.  
Classification.

Oscar Ruiz Chicote  
Person in charge of the area

Luis García Viguera  
The director department construction

The present certification is coincidental with the report of test N° 215108