



Certificate N° 215094


TESTS OF AIR PERMEABILITY, WATER TIGHTNESS AND WIND RESISTANCE

Company **Anicolor, Aluminios LDA.**
Oliveira do Bairro. Portugal

Procedure of test:
DIN EN 1026:2000. Windows and doors -
Air permeability - Test method
DIN EN 1027:2000. Windows and doors.
Watertightness. Test method.
DIN EN 12211:2000. Windows and doors.
Resistance to wind load. Test method.

Product	Flip-top window of vertical and horizontal low practicable draft to the interior of two leaves right.
Model	Series: AZ
Dimensions (AnxAI)	1800 mm x 2200 mm
Material	Aluminiio
Glass	4/12/4
Date of test	11.11.09

Section



Air Permeability	CLASS 3
Water Tightness	CLASS 8A
Wind resistance	CLASS C2



Procedure of classification:
DIN EN 12207:2000. Windows and doors.
Air permeability. Classification.
DIN EN 12208:2000. Windows and doors.
Watertightness. Classification.
DIN EN 12210:2000. Windows and doors.
Resistance to wind load. Classification.
DIN EN 12210/AC:2002. Windows and doors.
Resistance to wind load. Classification.

Oscar Ruiz Chicote
Person in charge of the area

Luis García Viguera
The director department construction

The present certification is coincidental with the report of test N° 215094