




Certificate N° 215098

**TESTS OF AIR PERMEABILITY, WATER TIGHTNESS AND WIND RESISTANCE**


Company	<b>Anicolor, Aluminios LDA. Oliveira do Bairro. Portugal</b>
Product	<b>Two-paned horizontal sliding window.</b>
Model	<b>Series: CP- Correr</b>
Dimensions (AnxAI)	<b>1230 mm x 1480 mm</b>
Material	<b>Aluminiio</b>
Glass	<b>4/8/4</b>
Date of test	<b>12.11.09</b>

Procedure of test:  
 DIN EN 1026:2000. Windows and doors - Air permeability - Test method  
 DIN EN 1027:2000. Windows and doors. Watertightness. Test method.  
 DIN EN 12211:2000. Windows and doors. Resistance to wind load. Test method.

Section



<b>Air Permeability</b>	<b>CLASS 3</b>
<b>Water Tightness</b>	<b>CLASS 7A</b>
<b>Wind resistance</b>	<b>CLASS C3</b>



Procedure of classification:  
 DIN EN 12207:2000. Windows and doors. Air permeability. Classification.  
 DIN EN 12208:2000. Windows and doors. Watertightness. Classification.  
 DIN EN 12210:2000. Windows and doors. Resistance to wind load. Classification.  
 DIN EN 12210/AC:2002. Windows and doors. Resistance to wind load. Classification.

Oscar Ruiz Chicote  
Person in charge of the area

Luis García Viguera  
The director department construction

The present certification is coincidental with the report of test N° 215098