



Certificate N° 213198

TESTS OF AIR PERMEABILITY, WATER TIGHTNESS AND WIND RESISTANCE


Company **Anicolor Aluminios LDA**
Oliveira do Bairro. Portugal

Procedure of test
DIN EN 1026:2000. Windows and doors -
Air permeability - Test method
DIN EN 1027:2000. Windows and doors -
Watertightness. Test method
DIN EN 12211:2000. Windows and
doors. Resistance to wind load. Test
method

Product
Two-paned horizontal sliding window.

Section

Model **Serie: Sistema CS**



Dimensions (AnxAI) **1230 mm x 1480 mm**

Material **Aluminio**

Glass **5/12/5**

Date of test **29.07.09**



Air Permeability CLASSE 3

Water Tightness CLASSE 6A

Wind resistance CLASSE C4



Procedure of classification
DIN EN 12207:2000. Windows and
doors. Air permeability. Classification.
DIN EN 12208:2000. Windows and
doors. Watertightness. Classification.
DIN EN 12210:2000. Windows and
doors. Resistance to wind load
Classification
DIN EN 12210/AC:2002. Windows and
doors. Resistance to wind load
Classification

Oscar Ruiz Chicote
Person in charge of the area

Luis García Viguera
The director department construction

José Morales Henares
General Manager

The present certification is coincidental with the report of test N° 213198