




Document N° 218472

TESTS OF AIR PERMEABILITY, WATER TIGHTNESS AND WIND RESISTANCE


Company	Anicolor, Aluminios LDA. Oliveira do Bairro. Portugal
Product	Four-paned horizontal slinding window.
Model	Series: CS
Dimensions (AnxAI)	2900 mm x 2200 mm
Material	Aluminiio
Glass	4/12/5
Date of test	12.04.10

Procedure of test:
 DIN EN 1026:2000. Windows and doors - Air permeability - Test method
 DIN EN 1027:2000. Windows and doors. Watertightness. Test method.
 DIN EN 12211:2000. Windows and doors. Resistance to wind load. Test method.

Section



Air Permeability	CLASS 3
Water Tightness	CLASS 6A
Wind resistance	CLASS C2



Procedure of classification:
 DIN EN 12207:2000. Windows and doors. Air permeability. Classification.
 DIN EN 12208:2000. Windows and doors. Watertightness. Classification.
 DIN EN 12210:2000. Windows and doors. Resistance to wind load. Classification.
 DIN EN 12210/AC:2002. Windows and doors. Resistance to wind load. Classification.

Oscar Ruiz Chicote
Person in charge of the area

Luis García Viguera
The director department construction

José Alvarez Burgué
The Technical director

The present certification is coincidental with the report of test N° 218472