



Certificate N° 213201


TESTS OF AIR PERMEABILITY, WATER TIGHTNESS AND WIND RESISTANCE

Company **Anicolor, Aluminios Lda.**
Zona Industrial Oiã, Apartado 6. Oiã.
Oliveira Do Bairro. Portugal.

Procedure of test
DIN EN 1026:2000 Windows and doors -
Air permeability - Test method
DIN EN 1027:2000 Windows and doors
Watertightness. Test method
DIN EN 12211:2000. Windows and
doors. Resistance to wind load. Test
method

Product
**Window balconera elevable deslizando
horizontal of two leaves(sheets) right.**

Model	Serie: Sistema Cte
Dimensions (AnxAI)	2800 mm x 2400 mm
Material	Aluminio
Glass	6/16/6
Date of test	29.07.09



Air Permeability **CLASSE 3**

Water Tightness **CLASSE 7A**

Wind resistance **CLASSE C2**



Procedure of classification
DIN EN 12207:2000. Windows and
doors. Air permeability. Classification
DIN EN 12208:2000. Windows and
doors. Watertightness. Classification
DIN EN 12210:2000. Windows and
doors. Resistance to wind load
Classification
DIN EN 12210-AC:2002. Windows and
doors. Resistance to wind load
Classification

Oscar Ruiz Chicote
Person in charge of the area

Luis García Viguera
The director department construction

José Morales Henares
General Manager

The present certification is coincidental with the report of test N° 213201